

AJAY NARAYAN PANDE
19, Aditya Nagar,
Near Venketesh Mangal karyalay
Garkheda AURANGABAD

Date: 15/03/2008

To Whom It May Concern:

We have replaced CPVC pipe within a year from installation which was used for solar lines at our banglow due to loosing of shape of CPVC pipe causing leakages at different points.

We replaced CPVC pipe with kitec composite pipe 2 years back. The till to date performance of the kitec pipe is fully satisfactory. The pipe is as it is till date.


Ajay.N.Pande
Mob No: 09881079363