

बृहन्मुंबई महानगरपालिका
BRIHANMUMBAI MAHANAGARPALIKA

Office of the
Hydraulic Engineer
Ground Floor, Annexe Bldg.,
Brihanmumbai Mahanagarpalika
Head Office, Fort,

No. : HE/1655/1C

Date : 14/9/98

To,

M/s. Kitec Industries (India)Ltd.,
C/18/11, Jeevan Bima Nagar,
Boriwali (W),
MUMBAI - 400 103.

Subj- Performance of ' KITEC' make
composite pipes.

• • • •


Dear Sir,

Please refer to your letter dated 8-10-1997.

The 'KITEC' make composite pipe pieces of length 3 to 3.5 m. and 3/4" dia. were laid underground in 'E' Ward for making water connection from distribution main in the month of October, 1996. On inspection after one year, it is found that the performance of the pipe over the period is satisfactory and there is no effect on the flow of water through these pipe.

Thanking you,

Yours


(S. N. TURKAR.)
Hydraulic Engineer