

A. G. KHATIWALA
EXECUTIVE ENGINEER



Phone : (O) 2535100
Fax: (0261) 2530564
North Zone(Katargam)
Surat Municipal Corporation

N. Z./Out/No.5029
Dt.18-12-2006


To,
Rachna Pipes,
Authorised Distributor : Kitec Composite Pipe,
Marvadi street,
Surat.395001.
NGULP4802

Subject :- Performance of " Kitec " make composite pipes.

Dear Sir,

Please refer to your letter dated 15-11-2006 The Kitec make composite Pipe Size of 3240, 2532 & 1216 (i.e.dia of 32 mm, 25mm & 12 mm respectively) were laid in T.P. Scheme No-1,F.P.No-33, 34 Slum area of Patelwadi No-2 The Job was done for making drinking water connection from distribution main in the month of January - 2001. 32 mm dia pipe was connected with main D.I. line & by means of 12 mm dia pipe connections of 1/2" dia were made.

On inspection it is found that the performance of pipe is satisfactory and there is no leakage in these pipes.


16/12/2006
Executive Engineer
North Zone (Katargam)
Surat Municipal Corporation